

Model K8AB-VS

Measuring & Monitoring Relay

English Instructions Manual

Thank you for purchasing an OMRON product. In this Instructions Manual, you will find information about this product's features, capabilities, and operating instructions. Please observe the following when using this product.

- This product is designed for use by qualified electrical engineer.
- Read and understand this Instructions Manual thoroughly, and make proper use of this product.
- Keep this Instructions Manual for future reference.

OMRON Corporation
© All Rights Reserved 9419059-7 C

Precautions for Safe Use

Make sure to follow the instructions below to ensure safety.

- Do not use or keep this product in the following environments.
 - Outdoors, or places subject to direct sunlight or wearing weather.
 - Places where dust, iron powder, or corrosive gases (in particular, sulfuric or ammonia gas) exist.
 - Places subject to static electricity or inductive noise.
 - Places where water or oil come in contact with the product.
- Make sure to install this product in the correct direction.
- There is a remote risk of electric shock. Do not touch terminals while electricity is being supplied.
- Make sure to thoroughly understand all instructions in the Instructions Manual before handling this product.
- Make sure to confirm terminal markings and polarity for correct wiring.
- Ensure that terminal screws have been tightened firmly. Recommended torque : 0.49 N · m Assured torque : 0.59 N · m
- Operating ambient temperature and humidity for this product must be within the indicated rating when using this product.
- There is a remote risk of explosion. Do not use this product where flammable or explosive gas exists.
- Make sure that no weight rests on the product after installation.
- To enable an operator to turn off this product easily, install switches or circuit breakers that conform to relevant requirements of IEC60947-1 and IEC60947-3, and label them appropriately.
- For DC input, use a SELV power-supply capable of overcurrent protection. Specifically, a SELV power-supply has a double or reinforced insulation for input and output, and output voltage of 30V r.m.s with 42.4V at peak or DC60V maximum. Recommended power-supply : Model S8VS-06024 (Omron product)
- Do not turn a setting volume beyond the scope of movement.

Precautions for Correct Use

- For Proper Use**
 - Do not use the product in the following locations.
 - Places subject to radiant heat from heat generating devices.
 - Places subject to vibrations or physical shocks.
 - Make sure to use setting values appropriate for the controlled object. Failure to do so can cause unintended operation, and may result in accident or corruption of the product.
 - Do not use thinner or similar solvent for cleaning. Use commercial alcohol.
 - When discarding, properly dispose of the product as industrial waste.
 - Only use this product within a board whose structure allows no possibility for fire to escape.
- About Installation**
 - When wiring, use only recommended crimp terminals.
 - Do not block areas around the product for proper dissipation of heat. (If you do not secure space for heat dissipation, life cycle of the product will be compromised.)
 - To avoid electrical shocks, make sure that power is not supplied to the product while wiring.
 - To avoid electrical shocks, make sure that power is not supplied to the product when performing DIP switch settings.

- Noise Countermeasures**
 - Do not install the product near devices generating strong high frequency waves or surges.
 - When using a noise filter, check the voltage and current and install it as close to the product as possible.
 - In order to prevent inductive noise, wire the lines connected to the product separately from power lines carrying high voltages or currents. Do not wire in parallel with or on the same cable as power lines. Other measures for reducing noise include running lines along separate ducts and using shield lines.
- To avoid faulty operations, malfunctions, or failure, observe the following operating instructions.**
 - When turning on the power, make sure to realize rated voltage within 1 second from the time of first supply of electricity.
 - Make sure to use power supply for operations, inputs, and transformer with the appropriate capacity and rated burden.
 - Maintenance and handling of this product may only be performed by qualified personnel.
 - Do not use this product with circuits that have distorted input wave forms. Distortion in wave forms will result in errors.
 - Using this product for thyristor controls or inverters will result in errors.
 - When setting the volume, adjust the control from the minimum side to the maximum side.

Applicable Standards

Installation environment	Installation Category III, Pollution Degree 2	
Application Standard	EN60255-5/-6	
Safety Standard	EN60664-1	
EMC	(EMI) EN61326+A1 Industrial applications	
	Terminal interference wave voltage CISPR11 Group1, ClassA : CISPR16-1/-2 Electromagnetic interference wave CISPR11 Group1, ClassA : CISPR16-1/-2	
	(EMS) EN61326+A1 Industrial applications	
	Electrostatic discharge	EN61000-4-2 : 4kV(Contact) 8kV(In air)
	Radiating radio-frequency electromagnetic field	EN61000-4-3 : 10V/m 1kHz Sine Wave Amplitude Modulation (80MHz to 1GHz)
	Burst	EN61000-4-4 : 2kV(Power Line) 1kV(I/O Signal line)
	Surge	EN61000-4-5 : 1kV with line (Power Line) 2kV with ground (Power Line)
	Conducted RF	EN61000-4-6 : 3V(0.15 to 80MHz)
	Power frequency magnetic field immunity	EN61000-4-8 : 30A/m
	Voltage dip/Short interruptions	EN61000-4-11 : 0.5 Cycle, 0.180" each polarity 100% (Rated Voltage)

Overview

This product is an electric controller for outputting an alarm upon detection of voltage. [1-phase Over or Under voltage Relay]

Specifications

Rating


Power Supply Voltage	DC24V, AC100/115V, AC200/230V, AC24V
Permissible Voltage Variability Range	85 to 110% of rated power-supply voltage
Power Consumption	DC24V : 1W maximum AC100/115V : 4VA maximum AC200/230V : 5VA maximum AC24V : 4VA maximum
Dielectric Resistance	20MΩ minimum (at 500V) Between electric circuit and case
Dielectric Withstanding Voltage	2000V for 1 minute Between electric circuit and case
Noise Immunity	±1,500V on power-supply terminals in normal or common mode (Square wave with 1 ns at rearing Pulse duration 1 μs/100ns)
Vibration Resistance	Vibrations : 10 to 55Hz, Acceleration : 50m/s ² , X,Y,Z Directions : 5 min X 10 scanning
Shock Resistance	150m/s ² (however, 100m/s ² at relay contact point) 3 times each in 3 axis and 6 directions
Input Range	-VS1 AC/DC 6-60/10-100/30-300mV -VS2 AC/DC 1-10/3-30/15-150V -VS3 AC/DC 20-200/30-300/60-600V
Input Impedance	-VS1 9kΩ minimum -VS2 100kΩ minimum -VS3 1MΩ minimum
Overload Capacity	115% of maximum input within range (continuous)/125%, 10s

Output Rating

Relay Output	Rated Load	Resistance Load : AC250V 6A, DC30V 6A
	Maximum Contact Point Voltage	AC250V, DC30V
	Maximum Contact Point Current	AC6A, DC6A
	Maximum Opening and Closing Capacity	1500VA, 180W
	Minimum Applicable Load (P Level)	DC5V, 10mA *Reference value
	Mechanical Life	10 million times minimum
Electrical Life (Ambient temperature condition : +20°C)	Make 50 thousand times, Break 30 thousand times	


Installation

Diagram of Outside Dimensions




Installation Procedure

- Pull down the hook, and then fasten the upper tab onto the rail, fitting in the unit until the hook locks into place.



Uninstallation Procedure

- Using a flathead screwdriver or a similar tool, pull out the hook downward and lift the unit from the bottom.



Fixing Bracket

- Attach the type K8AB to the DIN rail.
 - DIN Rail Type PFP-100N (1,000mm) Type PFP-50N (500mm)

Recommended Crimp Terminal


Recommended Crimp Terminal	Recommended Cable Diameter
AI 1,5-8BK (Phoenix Contact product)	AWG#16
AI 1-8RD (Phoenix Contact product)	AWG#18
AI 0,75-8GY (Phoenix Contact product)	AWG#18

List of DIP Switch settings


	SW			
	1	2	3	4
T1=5s	☐	☐	☐	☐
T1=1s	☐	☐	☐	☐
Auto Reset	☐	☐	☐	☐
Manual Reset	☐	☐	☐	☐
Normal Close	☐	☐	☐	☐
Normal Open	☐	☐	☐	☐
UNDER	☐	☐	☐	☐
OVER	☐	☐	☐	☐

☐ : ON
☐ : OFF

Time Chart




Terminal Connections



Name	Terminal Name	Description
Terminals	V1, V2, V3	Voltage input terminals
	C	Common for voltage input terminals
	A1, A2	Operative power supply
	11	Common for contact point output
Volume Settings	12	b-contact output
	14	a-contact output
	SV	Operate value setting (10 to 100%)
LED Indications	HYS.	Hysteresis setting (5 to 50%)
	T	Operate time setting (0.1 to 30s)
LED Indications	PWR	Power indication
	RY	Relay output status Light-on 11-14 conduction
LED Indications	ALM	Alarm operation status Light-on = Alarm output status

Wiring Diagram



* Connect the input between terminals V1-COM, V2-COM, V3-COM depending on the input voltage

Suitability for use

OMRON shall not be responsible conformity with any standards, codes, or regulations that apply to the combination of the products in the customer's application or use of the product. Take all necessary steps to determine the suitability of the product for the systems, machines, and equipment with which it will be used. Know and observe all prohibitions of use applicable to this product. NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM. See also Product catalog for Warranty and Limitation of Liability.

Contact Information

OMRON ELECTRONICS LLC
Phone : 1-847-843-7900 Fax : 1-847-843-7787
OMRON CANADA INC.
Phone : 1-416-286-6465 Fax : 1-416-286-6648
Phone : 1-514-636-6676 (French Language)
Fax : 1-514-036-2959
EUROPEAN H.Q. : OMRON EUROPE B.V.
Phone : 31-23-56-81-300 Fax : 31-23-56-81-388
OMRON ELECTRONICS PTY. LTD
Phone : 61-2-9878-6377 Fax : 61-2-9878-6981
OMRON ASIA-PACIFIC PTE LTD
Phone : 65-6-835-3011 Fax : 65-6-835-2711